

**Part III Form 2  
Section 11. ANNUAL REPORT.**

<b>Drinking-Water System Number:</b>	260021034
<b>Drinking-Water System Name:</b>	Puslinch Community Centre
<b>Drinking-Water System Owner:</b>	Township of Puslinch
<b>Drinking-Water System Category:</b>	SMNR – Small Municipal Non-Residential
<b>Period being reported:</b>	January 1, 2009 to December 31, 2009

<p><b><u>Complete if your Category is Large Municipal Residential or Small Municipal Residential</u></b></p> <p>Does your Drinking-Water System serve more than 10,000 people? Yes [ ] No [ ]</p> <p>Is your annual report available to the public at no charge on a web site on the Internet? Yes [ ] No [ ]</p> <p>Location where Summary Report required under O. Reg. 170/03 Schedule 22 will be available for inspection.</p> <div style="border: 1px solid black; height: 100px; width: 100%;"></div>	<p><b><u>Complete for all other Categories.</u></b></p> <p>Number of Designated Facilities served: <span style="border: 1px solid black; padding: 2px 10px;">1</span></p> <p>Did you provide a copy of your annual report to all Designated Facilities you serve? Yes [ X ] No [ ]</p> <p>Number of Interested Authorities you report to: <span style="border: 1px solid black; padding: 2px 10px;">3</span></p> <p>(Puslinch Community Centre, Library and Whistlestop Preschool)</p> <p>Did you provide a copy of your annual report to all Interested Authorities you report to for each Designated Facility? Yes [ X ] No [ ]</p>
-------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------	---------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------

**Note: For the following tables below, additional rows or columns may be added or an appendix may be attached to the report**

List all Drinking-Water Systems (if any), which receive all of their drinking water from your system:

Drinking Water System Name	Drinking Water System Number
Puslinch Community Centre, Whistlestop Preschool, Library, Concession Booth	260021034

Did you provide a copy of your annual report to all Drinking-Water System owners that are connected to you and to whom you provide all of its drinking water? Yes [ X ] No [ ]

Indicate how you notified system users that your annual report is available, and is free of charge.

- Public access/notice via the web
- Public access/notice via Government Office
- Public access/notice via a newspaper
- Public access/notice via Public Request
- Public access/notice via a Public Library
- Public access/notice via other method

**Describe your Drinking-Water System**

Softener and UV system.

**List all water treatment chemicals used over this reporting period**

N/A

**Were any significant expenses incurred to? N/A**

- Install required equipment
- Repair required equipment
- Replace required equipment

**Please provide a brief description and a breakdown of monetary expenses incurred**

**Provide details on the notices submitted in accordance with subsection 18(1) of the Safe Drinking-Water Act or section 16-4 of Schedule 16 of O.Reg.170/03 and reported to Spills Action Centre**

Incident Date	Parameter	Result	Unit of Measure	Corrective Action	Corrective Action Date
N/A					

**Microbiological testing done under the Schedule 10, 11 or 12 of Regulation 170/03, during this reporting period.**

	Number of Samples	Range of E.Coli Or Fecal Results (min #)-(max #)	Range of Total Coliform Results (min #)-(max #)	Number of HPC Samples	Range of HPC Results (min #)-(max #)
Raw	29	0	0	0	0
Treated	122	0	0	122	<10 – 90
Distribution	N/A				

**Operational testing done under Schedule 7, 8 or 9 of Regulation 170/03 during the period covered by this Annual Report.**

	Number of Grab Samples	Range of Results (min #)-(max #)
Turbidity	0	
Chlorine	0	
Fluoride (If the DWS provides fluoridation)	0	

*NOTE: For continuous monitors use 8760 as the number of samples.*

*NOTE: Record the unit of measure if it is not milligrams per litre.*

**Summary of additional testing and sampling carried out in accordance with the requirement of an approval, order or other legal instrument.**

Date of legal instrument issued	Parameter	Date Sampled	Result	Unit of Measure
N/A				

**Summary of Inorganic parameters tested during this reporting period or the most recent sample results**

Parameter	Sample Date	Result Value	Unit of Measure	Exceedance
Antimony	Oct 22/07	0.02 <MDL	ug/L	
Arsenic	Oct 22/07	0.2	ug/L	
Barium	Oct 22/07	0.27	ug/L	
Boron	Oct 22/07	17	ug/L	
Cadmium	Oct 22/07	0.003 <MDL	ug/L	
Chromium	Oct 22/07	0.5 <MDL	ug/L	
Lead	Oct 20/09	4.03/0.48	ug/L	
Mercury	Oct 22/07	0.02 <MDL	ug/L	
Selenium	Oct 22/07	1 <MDL	ug/L	
Sodium	Oct 22/07	136 MAC	mg/L	136 MAC
Uranium	Oct 22/07	0.143	ug/L	
Fluoride	Oct 22/07	0.45	mg/L	
Nitrite	Nov 30/09	0.005 <MDL	mg/L	
Nitrate	Nov 30/09	0.013 <MDL	mg/L	

**Summary of Organic parameters sampled during this reporting period or the most recent sample results**

Parameter	Sample Date	Result Value	Unit of Measure	Exceedance
Alachlor	Oct 22/07	0.11	ug/L	
Aldicarb	Oct 22/07	0.30	ug/L	
Aldrin + Dieldrin	Oct 22/07	0.067	ug/L	
Atrazine + N-dealkylated metabolites	Oct 22/07	0.12	ug/L	
Azinphos-methyl	Oct 22/07	0.21	ug/L	
Bendiocarb	Oct 22/07	0.13	ug/L	
Benzene	Oct 22/07	0.37 <MDL	ug/L	
Benzo(a)pyrene	Oct 22/07	0.004	ug/L	
Bromoxynil	Oct 22/07	0.33	ug/L	
Carbaryl	Oct 22/07	0.16	ug/L	
Carbofuran	Oct 22/07	0.37	ug/L	
Carbon Tetrachloride	Oct 22/07	0.41 <MDL	ug/L	
Chlordane (Total)	Oct 22/07	0.11	ug/L	
Chlorpyrifos	Oct 22/07	0.18	ug/L	
Cyanazine	Oct 22/07	0.18	ug/L	
Diazinon	Oct 22/07	0.081	ug/L	
Dicamba	Oct 22/07	0.20	ug/L	
1,2-Dichlorobenzene	Oct 22/07	0.50 <MDL	ug/L	
1,4-Dichlorobenzene	Oct 22/07	0.21 <MDL	ug/L	
Dichlorodiphenyltrichloroethane (DDT) + metabolites	Oct 22/07	0.14	ug/L	
1,2-Dichloroethane	Oct 22/07	0.43 <MDL	ug/L	
1,1-Dichloroethylene (vinylidene chloride)	Oct 22/07	0.41 <MDL	ug/L	
Dichloromethane	Oct 22/07	0.34 <MDL	ug/L	
2-4 Dichlorophenol	Oct 22/07	0.15	ug/L	
2,4-Dichlorophenoxy acetic acid (2,4-D)	Oct 22/07	0.19	ug/L	
Diclofop-methyl	Oct 22/07	0.40	ug/L	
Dimethoate	Oct 22/07	0.12	ug/L	
Dinoseb	Oct 22/07	0.36	ug/L	
Diquat	Oct 22/07	1	ug/L	
Diuron	Oct 22/07	0.087	ug/L	
Glyphosate	Oct 22/07	6	ug/L	
Heptachlor + Heptachlor Epoxide	Oct 22/07	0.11	ug/L	
Lindane (Total)	Oct 22/07	0.056	ug/L	
Malathion	Oct 22/07	0.091	ug/L	
Methoxychlor	Oct 22/07	0.14	ug/L	
Metolachlor	Oct 22/07	0.092	ug/L	
Metribuzin	Oct 22/07	0.12	ug/L	
Monochlorobenzene	Oct 22/07	0.58	ug/L	
Paraquat	Oct 22/07	1	ug/L	
Parathion	Oct 22/07	0.18	ug/L	

Pentachlorophenol	Oct 22/07	0.15	ug/L	
Phorate	Oct 22/07	0.11	ug/L	
Picloram	Oct 22/07	0.25	ug/L	
Polychlorinated Biphenyls(PCB)	Oct 22/07	0.04	ug/L	
Prometryne	Oct 22/07	0.23	ug/L	
Simazine	Oct 22/07	0.15	ug/L	
THM (NOTE: show latest annual average)				
Temephos	Oct 22/07	0.31	ug/L	
Terbufos	Oct 22/07	0.12	ug/L	
Tetrachloroethylene	Oct 22/07	0.45	ug/L	
2,3,4,6-Tetrachlorophenol	Oct 22/07	0.14	ug/L	
Triallate	Oct 22/07	0.10	ug/L	
Trichloroethylene	Oct 22/07	0.38	ug/L	
2,4,6-Trichlorophenol	Oct 22/07	0.25	ug/L	
2,4,5-Trichlorophenoxy acetic acid (2,4,5-T)	Oct 22/07	0.22	ug/L	
Trifluralin	Oct 22/07	0.12	ug/L	
Vinyl Chloride	Oct 22/07	0.17	ug/L	

**List any Inorganic or Organic parameter(s) that exceeded half the standard prescribed in Schedule 2 of Ontario Drinking Water Quality Standards.**

Parameter	Result Value	Unit of Measure	Date of Sample
N/A			

**(Only if DWS category is large municipal residential, small municipal residential, large municipal non residential, non municipal year round residential, large non municipal non residential)**