



PUSLINCH FIRE AND RESCUE

7404 Wellington Rd 34, RR #3 Guelph, ON, N1H 6H9

Fire Chief Robert Gordon
Deputy Chief Steve Goode
Telephone 519 821 3010
Fax 519 836 6421
Cell 519 837 6090

August 18, 2010

To Whom It May Concern:

The certificate attached from Fire Protection Survey Services confirms that we have obtained the Superior Tanker Shuttle Service Accreditation.

We have obtained both the residential rating and the commercial rating.

If you have any further questions please contact us.

Yours truly,

Robert Gordon
Fire Chief

Fire Protection Survey Services™

6515 Rama Road, General Delivery
Longford Mills, Ontario, Canada, L0K 1L0
Telephone: (705) 326-0783 Fax: (208) 474-3520
Cell Phone: (705) 323-6248 E-mail: firepss@sympatico.ca
Website: www.fpss.ca

August 17, 2009

Township of Puslinch
Fire & Rescue
7404 Wellington Rd. 34
R. R. # 3
Guelph, ON
N1H 6H9

Subject: Fire Department Water Tanker Shuttle Accreditation
(Formerly referred to as: Superior Tanker Shuttle Service Accreditation)

Fire Protection Survey Services is pleased to award your municipality with **Fire Department Water Tanker Shuttle Accreditation** (Formerly referred to as: Superior Tanker Shuttle Service Accreditation).

The test procedure was carried out on September 15, 2007 with the undersigned present. The flow rate during the 2-hour test period averaged 2,045 litres per minute or 450 Imperial gallons per minute.

Your team worked in a well co-ordinated and organized manner with proper supervision.

Your municipality will require re-certification by October 01, 2012.

Regards,



Peter J. Rose, C.E.T., F.P.T.
Principal Associate
Senior Fire Protection Specialist
Loss Control Specialist

